

CERTIFICATE

for

TÜV PROFiCERT-product Interior PREMIUM

The following product/product group particularly fulfills the criteria V1.3 of the TÜV PROFiCERT-product Interior certification. This certificate does not acquit the producer of his responsibility to comply with all legal requirements and product properties.


EGGER Holzwerkstoffe Wismar GmbH & Co. KG
 Am Haffeld 1
 D-23970 Wismar
 Germany

Egger Comfort flooring UC 31 - 32

Result of quality testing: Classification requirements according to EN 16511:2014+A1:2019 for the classes 31 - 32 are fulfilled

Result of the emission testing: TÜV PROFiCERT-product Interior PREMIUM fulfilled

Thus, the results comply with the emission thresholds of

√ AgBB 2018	√ BREEAM Exemplary Level	√ Austrian Ecolabel, Guideline UZ 07
√ 	√ Finnish M1 classification	√ DE-UZ 176 (Blue Angel)
√ Belgian VOC regulation	√ Annex 8 MVV TB / ABG	√ CAM Italy
√ LEED v4 (outside North America)		


Certificate registration No. **70 720 6151-2**

Certificate valid from 2021-11-06 to **2024-11-05**

Audit report No. 2117289/1/2021

First certification 2018-11-06




 Darmstadt, 2021-11-18
 Certification body of TÜV Hessen
 – Head of Certification body –

ANNEX

This article / this group is characterized by the following features (all data $\pm 10\%$):

Utilisation class:	31 / 32
Wear layer:	UC31 / UC32
Decor layer:	UV-curing acrylic varnish
Interlayer:	Cork in thickness 1.2 mm
Carrier layer:	HDF, thickness 6 – 8 mm, average density 900 kg/m ³
Back layer:	Cork in thickness 0.9 mm
V-joint:	Without / 4-sided
Sound insulation:	integrated cork
Total thickness:	8.0 – 10.0 mm
Area weight:	8.1 – 6.5 kg/m ²

and comprises the following articles:

EGGER Home Comfort
EGGER Pro Comfort UC31
EGGER Pro Comfort UC32

TÜV PROFICERT-product Interior PREMIUM

Certificate registration No. **70 720 6151-2**

Certificate valid from 2021-11-06 to **2024-11-05**



O. Mehl

Darmstadt, 2021-11-18
Certification body of TÜV Hessen
– Head of Certification body –