

CERTIFICATE

for

TÜV PROFiCERT-product Interior PREMIUM

The following product/product group particularly fulfills the criteria V1.3 of the TÜV PROFi-CERT-product Interior certification. This certificate does not acquit the producer of his responsibility to comply with all legal requirements and product properties.

> EGGER Holzwerkstoffe Wismar GmbH & Co. KG Am Haffeld 1 D-23970 Wismar Germany

Egger Design flooring UC 33

Result of quality testing: Classification requirements according to

EN 16511:2014+A1:2019 for the class 33 are fulfilled

Result of the emission testing: TÜV PROFICERT-product Interior PREMIUM fulfilled

Thus, the results comply with the emission thresholds of

√	AgBB 2018	√	BREEAM Exemplary Level	√	Austrian Ecolabel, Guideline UZ 07
√	A+	√	Finnish M1 classification	√	DE-UZ 176 (Blue Angel)
√	Belgian VOC regulation	√	Annex 8 MVV TB / ABG	√	CAM Italy
√	LEED v4 (outside North America)				

Certificate registration No. 70 720 6151-3

Certificate valid from 2021-11-06 to 2024-11-05

Audit report No. 2117289/1/2021

First certification 2018-11-06





Darmstadt, 2021-11-18
Certification body of TÜV Hessen
- Head of Certification body -



ANNEX

This article / this group is characterized by the following features (all data \pm 10 %):

Utilisation class (UC): 33

Wear layer: UC 34, Polypropylene film coated with UV-lacquer

Decor layer: Decorative paper impregnated with melamine resin

Carrier layer: HDF, thickness 5.8 mm, average density 960 kg/m³

Back layer: Kraft paper impregnated with melamine resin

V-joint: 4-sided

Sound insulation: integrated cork layer 0.9 mm

Total thickness: 7.5 mm

Area weight: $6.5 - 7.0 \text{ kg/m}^2$

and comprises the following articles:

EGGER PRO Design Flooring Green Tec EGGER HOME Design Flooring Green Tec

TÜV PROFICERT-product Interior (PREMIUM)

Certificate registration No. 70 720 6151-3

Certificate valid from 2021-11-06 to 2024-11-05





Darmstadt, 2021-11-18 Certification body of TÜV Hessen – Head of Certification body –